

## 2023 Consumer Confidence Report for Public Water System ELM RIDGE WCID

This is your water quality report for January 1 to December 31, 2023

ELM RIDGE WCID provides surface water and ground water from Lewisville Lake and Chapman Lake located in Delta and Hopkins Counties.

For more information regarding this report contact:

Name: Chris Cox

Phone: 972-544-7115

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (972) 544-7115.

### Definitions and Abbreviations

Definitions and Abbreviations

The following tables contain scientific terms and measures, some of which may require explanation.

Action Level:

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Avg:

Regulatory compliance with some MCLs is based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of disinfectant is allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL

million fibers per liter (a measure of asbestos)

mrem:

millirems per year (a measure of radiation absorbed by the body)

na:

not applicable.

NTU

nephelometric turbidity units (a measure of turbidity)

pCi/L

picocuries per liter (a measure of radioactivity)

## Definitions and Abbreviations

ppb:	micrograms per liter or parts per billion
ppm:	milligrams per liter or parts per million
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

## Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### Information about Source Water

ELM RIDGE WCID purchases water from UTRWD REGIONAL WATER TREATMENT PLANT. UTRWD REGIONAL WATER TREATMENT PLANT provides purchase surface water from Lewisville Lake and Chapman Lake located in Delta and Hopkins Counties.

Date	Substance	Maximum Amount in UTRWD Water	Range in UTRWD Water	MCL	MCLG	Possible Source
Regulated at the Treatment Plant						
2023	Arsenic (ppb)	1.5	0 – 1.5	10 ppm	0 ppm	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
2023	Barium (ppm)	0.044	0.04 – 0.044	2 ppm	2 ppm	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
2023	Bromate* (ppb)	5.5	2 – 7.5	10 ppb	0 ppb	By-product of drinking water disinfection.
2023	Chromium (ppb)	1.9	0 – 1.9	100 ppb	100 ppb	Discharge from steel and pulp mills; erosion of natural deposits.
2023	Cyanide (ppb)	154	68.7 – 154	200 ppb	200 ppb	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories.
2023	Fluoride** (ppm)	0.287	0.183 – 0.287	4 ppm	4 ppm	Erosion of naturally occurring deposits; Discharge from fertilizer and aluminum factories.
2023	Nitrate	0.774	0.2 – 0.774	10 ppm	10 ppm	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.
2023	Turbidity *** (NTU)	0.22	0.06 – 0.22	0.3 NTU	n/a	Soil runoff.
Radioactive Contaminants						
2023	Beta/photon emitters**** (pCi/L)	4.2	4.2 – 4.2	50 (pCi/L)	0 (pCi/L)	Soil runoff.
Synthetic Organic Chemicals Including Pesticides and Herbicides						
2023	Atrazine (ppb)	0.1	0 – 0.1	3 ppb	3 ppb	Runoff from herbicide used on row crops.
2023	Simazine (ppb)	0.08	0 – 0.08	4 ppb	4 ppb	Herbicide runoff.

**\*\*UTRWD does not add fluoride to its water.**

**\*\*\*100% of samples were below the 0.3 NTU turbidity limit.**

**\*\*\*\* EPA considers 50 pCi/L to be the level of concern for beta particles.**

TCEQ completed an assessment of your source water, and results indicate that our sources have a low susceptibility to contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact Chris Cox at 972-544-7115.

The Elm Ridge WCID reported a water loss of 7.8% to the Texas Water Development Board.

### Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1	0	0	N	Naturally present in the environment.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	08/25/2021	1.3	1.3	0.096	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	08/25/2021	0	15	5	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.